

LIST OF ALL FACILITIES ON SITE
Law Engineering Inc.
AUSTIN PEAY STATE UNIVERSITY
CLARKSVILLE, TENNESSEE
1995
OUTSTANDING COMPLIANCE ITEMS
FOR ACADEMIC/ADMINISTRATION BUILDINGS

file
ADA
Cross file
Disability Commit

Building Name

1. 219 Castle Heights
 - a. Refine accessible parking and install sign
 - b. Construct accessible pathway
 - c. Install ramp
 - d. Replace/add handrail
 - e. Modify entrance platform and door hardware
 - f. ~~Modify doorways~~
 - g. Construct new toilet room

- ~~2. 227 Castle Heights~~

- ~~3. 228 Castle Heights — Demolished~~

- ~~4. 302 Castle Heights — Demolished~~

- ~~5. Archwood — Renovated and the Code Compliance Issues have been completed~~
 - ~~a. Redefine parking~~
 - ~~b. Install new ramp~~
 - ~~c. Modify ramp at entrance and enlarge doorway~~
 - ~~d. Modify doors, controls, alarms and hardware~~
 - ~~e. Modify handrails~~
 - ~~f. Provide accessible toilet room on each floor~~
 - ~~g. Lower counter top~~

6. Browning Administration
 - a. ~~Redefine accessible parking — Completed~~
 - b. ~~Rebuild/modify entrance ramps/steps — Completed~~
 - c. Replace doors
 - d. Enlarge platforms
 - e. Install new elevator
 - f. ~~Replace doors/hardware~~
 - g. ~~Modify fountains~~
 - h. ~~Add/replace ramps~~
 - i. Replace railings
 - j. Modify fixtures and accessories in existing toilet rooms and toilet room in basement
 - k. Make cashiers counter accessible

~~7. CEH Cafeteria—The cafeteria has been moved to the new University Center and the New Bookstore project has been completed. All complaint issues have been addressed.~~

- ~~a. Widen entrance door to office and add signage~~
- ~~b. Modify fixtures and accessories in toilet rooms~~
- ~~c. Redefine parking~~
- ~~d. Rebuild patch section~~
- ~~e. Replace ramp handrails~~
- ~~f. Install sign~~

8. Claxton Building

- a. Redefine parking
- b. Rebuild sloping pathway
- c. Install ramp
- d. Replace door at lecture hall entrance
- e. Install signage
- f. Modify elevator controls and signals
- g. Modify doors, fountains, controls and signage
- h. Replace handrails
- i. Rebuild ramp
- j. Modify toilet room doors/fixtures/accessories
- k. Install listening system in lecture hall

~~9. Clement Fine Arts—Renovated in 1999—All compliant issues have been addressed~~

- ~~a. Define parking access aisles~~
- ~~b. Build curb ramps~~
- ~~c. Rebuild ramp~~
- ~~d. Enlarge platform~~
- ~~e. Replace door~~
- ~~f. Install signs at non-accessible entrances~~
- ~~g. Modify elevator controls/signals/accessories~~
- ~~h. Modify doors/signs/controls/fountains~~
- ~~i. Modify stair handrails~~
- ~~j. Rebuild ramp~~
- ~~k. Modify toilet room doors/stalls/fixtures and accessories~~
- ~~l. Modify seating~~
- ~~m. Add listening system in auditorium~~

10. Dunn Center

- a. Site accessibility
- b. Entrance accessibility
- c. Building accessibility
- d. Spaces accessibility

11. E.H. Alumni Center—Renovated in 2001—All compliance issues have been completed

- a. Build accessible parking
- b. Build pathway to side entrance
- c. Install ramps
- d. Modify steps and handrails

- ~~e. Modify door hardware and threshold~~
- ~~f. Modify signage/stair handrails~~
- ~~g. Construct accessible toilet room~~

12. Ellington Hall

- ~~a. Redefine parking~~
- b. Rebuild ramp
- c. Modify step handrails
- d. Replace doors/hardware/thresholds
- e. Modify elevator controls and accessories
- f. Modify doors
- g. Replace handrails
- ~~h. Modify toilet room doors/fixtures and accessories~~

~~13. Greenhouse~~

14. Harned Hall

- ~~a. Redefine parking~~
- ~~b. Install curbcut~~
- c. Install handrails at entrance ramp
- d. Replace double leaf doors
- ~~e. Install signs~~
- f. Replace existing elevator
- g. Replace doors
- h. Widen corridor sections
- i. Modify stairs/handrails
- j. Install 2 new ramps
- k. Modify toilet room fixtures/accessories
- l. Construct new men's toilet on 1st floor

~~15. Joe Morgan University Center - Old Facility Demolished~~

16. Kimbrough

- ~~a. Install signage at parking/entrances~~
- ~~b. Install curbcut~~
- c. Construct new stairs throughout building
- d. Modify elevator controls/signals, accessories
- e. Replace doors/hardware/fountains
- f. Modify controls/signage
- g. Modify toilet room doors/fixtures and accessories
- h. Provide accessible spaces in lecture hall

17. Marks Industrial – *State Approved Renovations*

- ~~a. Resurface and redefine accessible parking~~
- ~~b. Modify pathways~~
- ~~c. Reverse door swing~~
- ~~d. Replace hardware~~
- ~~e. Modify doors/fountains/signage/controls~~
- ~~f. Modify stairs and handrails~~

- ~~g. Construct ramps~~
- ~~h. Modify doors, fixtures and accessories or construct new toilet rooms~~

18. McCord Science – *Renovation In Progress*

- ~~a. Define accessible parking spaces~~
- ~~b. Modify existing ramp~~
- ~~c. Replace doors~~
- ~~d. Modify step handrails~~
- ~~e. Replace existing elevator~~
- ~~f. Modify doors/fountains/signage~~
- ~~g. Modify handrails~~
- ~~h. Install new ramp~~
- ~~i. Modify existing toilet room doors/fixtures and accessories~~

19. McReynolds Hall – *State Approved Renovations*

- ~~a. Widen pathway~~
- ~~b. Modify entrance ramp and doorway~~
- ~~c. Construct new elevator and modify stair handrails~~
- ~~d. Modify doors, fountains, signs, controls~~
- ~~e. Install ramp/ new handrails at corridor steps~~
- ~~f. Modify or replace toilet rooms; enlarge doorways~~

20. Memorial Health

- ~~a. Define accessible parking, add curbeuts~~
- b. Replace door, install signage
- ~~c. Enlarge door openings~~
- d. Modify doors, fountain and signage
- ~~e. Provide accessible toilet rooms, showers, rec. room~~

21. Music/Mass Communications

- ~~a. Relocate accessible parking~~
- ~~b. Modify curbeuts~~
- c. Rebuild steps
- d. Modify ramp
- ~~e. Replace door closer~~
- ~~f. Install signage~~
- g. Modify elevator controls/accessories
- h. Modify doors/fountains/signage/controls
- i. Modify stair handrails
- j. Modify toilet room doors/fixtures and accessories
- k. Provide accessible spaces/listening system

~~22. Power House~~

~~23. President's Home – Dunbar Cave Road – Sold~~

24. R.C. Shasteen Building

- ~~a. Redefine accessible parking~~
- b. Install curbcut
- ~~c. Replace door closer~~
- d. Install signs at inaccessible entrances
- e. Replace door hardware
- f. Install new drinking fountain
- g. Construct wing wall
- h. Modify existing toilet rooms
- i. Construct new toilet rooms

~~25. ROTC Armory— Facility to be Demolished in 2005~~

- ~~a. Define accessible parking~~
- ~~b. Modify curbcuts/pathways~~
- ~~c. Install ramp~~
- ~~d. Install new ramp/new handrails at steps~~
- ~~e. Replace doors~~
- ~~f. Modify doors/fountains/signage~~
- ~~g. Provide accessible toilet/shower facilities~~

26. Child Learning Center at Sexton

- ~~a. Define accessible parking~~
- ~~b. Construct drop-off~~
- ~~c. Modify curbcuts~~
- d. Replace doors
- e. Modify doors/fountain/controls/signage
- f. Modify toilet room doors/fixtures and accessories
- ~~g. Lower countertop in lobby~~

27. Stadium

- ~~a. Define accessible spaces~~
- ~~b. Install curbcut~~
- ~~c. Replace sites and install new ramps~~
- d. Install wing walls
- e. Provide accessible toilet rooms/spectator seating and ticket windows

28. Tennis Center

- ~~a. Install new sign~~
- ~~b. Install new curbcut~~
- c. Add or enlarge platform
- d. Replace door opening hardware
- e. Replace threshold
- f. Install 2 exterior signs
- g. Replace toilet
- h. Construct new shower

29. Trahern Art-Drama

- a. Provide accessible parking and passenger loading zones
- b. Repair automatic door opener

- c. Replace/remove thresholds
- d. Install signs
- e. Replace existing elevator
- f. Modify doors/fountains/controls/signage
- g. Modify/add ramps
- h. Modify handrails
- i. Modify toilet room doors/fixtures and accessories
- j. Install accessible showers
- k. Provide accessible seating/listening system in auditorium

~~30. University Farm~~

31. Warehouse

- a. Construct ramp at entrance
- b. Install handrails for steps
- c. Replace hardware
- d. Construct accessible toilet room
- e. Install new fountain
- ~~f. Provide accessible parking~~

32. Woodward Library – *Renovations Pending State Approval*

- a. Replace elevator
- b. Replace drink fountains
- c. Relocate controls and signs
- d. Create accessible stalls in toilet rooms
- e. Modify accessories and fixtures
- f. Lower 36" section of check out counter

~~33. Zeigler – Demolished~~

HOUSING BUILDINGS

1. Blount Hall

- a. Modify handrails at steps
- b. Install new ramp
- c. Replace ~~opening hardware and~~ threshold
- d. Install signage
- e. Build wing walls
- ~~f. Replace drinking fountains~~
- g. Modify stair handrails
- h. Construct accessible bathrooms
- i. Provide accessible cabinets, counters and appliances in kitchen
- j. Lower clothes rods

2. Cross Hall – *Planned for demolition*

- ~~a. Define parking~~
- ~~b. Construct curbcut/ramp~~
- ~~e. Modify ramps~~

- ~~d. Enlarge platforms~~
- ~~e. Enlarge door openings~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible toilet, bathing, laundry, and kitchen facilities~~
- ~~h. Make clothes rods accessible~~

3. Emerald Hills 1 through 12

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- c. Enlarge platforms at doors
- d. Modify hardware/thresholds
- e. Enlarge door
- f. Replace stair handrails
- g. Provide accessible restrooms/kitchens and closets in accessible units
- h. Make office/laundry facilities accessible

4. Emerald Hills 2

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

5. Emerald Hills 3

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

6. Emerald Hills 4

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

7. Emerald Hills 5

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~

- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

~~8. Emerald Hills 6~~

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

~~9. Emerald Hills 7~~

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

~~10. Emerald Hills 8~~

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

~~11. Emerald Hills 9~~

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

~~12. Emerald Hills 10~~

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~

- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

13. ~~Emerald Hills 11~~

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

14. ~~Emerald Hills 12~~

- ~~a. Provide accessible parking~~
- ~~b. Install curbeuts~~
- ~~e. Enlarge platforms at doors~~
- ~~d. Modify hardware/thresholds~~
- ~~e. Enlarge door~~
- ~~f. Replace stair handrails~~
- ~~g. Provide accessible restrooms/kitchens and closets in accessible units~~
- ~~h. Make office/laundry facilities accessible~~

15. ~~Harvill Hall~~

16. Killebrew Hall – *Planned for demolition*

- ~~a. Modify parking/pathways~~
- ~~b. Install handrails and new ramps~~
- ~~c. Enlarge doorways for accessible dorm rooms~~
- ~~d. Modify stair handrails~~
- ~~e. Provide accessible bathrooms~~
- ~~f. Provide accessible dorm rooms/lobby and laundry facility~~

17. Meacham Apartments

- a. Provide accessible stairs
- b. ~~Redefine accessible parking spaces~~, install ramp handrails
- c. Provide accessible entry into lobby and laundry room
- d. Install a front loading washer
- e. Provide accessible apartment toilet room, showers, etc.

18. Miller Hall

- ~~a. Modify parking and pathways~~
- b. Install railing/new ramp
- c. Provide entrance platform
- d. Modify hardware/threshold
- e. Install elevator

- f. Modify doors
- g. Install handrails/new ramp
- h. Modify toilet room/fixtures/doors and accessories
- i. Provide accessible showers/dorm rooms/laundry room/kitchen

19. Rawlins Hall – *Planned for Demolition*

- ~~a. Redefine 4 accessible parking spaces and mount signs~~
- ~~b. Improve or add 4 curbs to pathways from park to building and building to building~~
- ~~c. Replace door opening hardware~~
- ~~d. Modify threshold~~
- ~~e. Enlarge entrance platform~~
- ~~f. Install a new elevator and shaft outside the building~~
- ~~g. Replace steps at center stairwell for end stairwells~~
- ~~h. Replace handrails~~
- ~~i. Fill in open risers~~

20. Sevier Hall

- ~~a. Define accessible parking~~
- b. Install new ramp
- c. Modify handrails
- d. Modify hardware/threshold/signs
- e. Build elevator
- f. Modify doors/fountains/controls/signs
- g. Modify stair handrails
- h. Modify existing toilet room and showers
- i. Provide accessible clothes rods/lobby/laundry room/kitchen

21. Two Rivers Apartments

- a. Modify bathroom/kitchen and closet to make one apartment accessible
- b. Enlarge door ways in apartment
- c. Replace handrails at steps
- d. Provide a ramp
- e. Modify hardware and threshold for entrance to accessible unit
- ~~f. Define accessible parking space~~